

**KEROSENE (REGULAR)**  
**(BS 2869, Class C2)**  
**Product Specification**

	<b>Units</b>	<b>Min</b>	<b>Max</b>	<b>Test Method</b>
Density @ 15°C	g/ml		0.820	D1298/160
Appearance	Clear and bright, free from visible sediment and water			Visual
Odour	Merchantable			-
<b>Distillation</b> Rec @ 200°C Rec @ 210°C Rec @ 240°C FBP Residue	%vol %vol %vol °C %vol	15  50	90  300 2	BS 7392
Flash Point	°C	38		BS EN ISO 13736
Smoke Point	mm	19		BS 2000-57
Sulphur	%wt		0.20	BS EN ISO 8754
Copper Corrosion (3hrs @ 100 °C)	Class		1	BS EN ISO 2160
Char Value	mg/kg		20	BS 2000-10
Kinematic Viscosity @ 40°C	cSt	1.0	2.0	BS EN ISO 3104
Doctor Test		Negative		-/30
Or Mercaptan Sulphur	%wt		0.0020	D3227/342

1) This product will be marked with HM C&E statutory marker.

Revised January 2003